



**Certificate number: 2504732 (1)**

Issued 23/04/2025

Expires 23/04/2030

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### WaterSaver Labtaps Limited.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

**Kiwa Watertec**  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
WaterSaver Labtaps Limited  
Unit 11 High Carr Network Centre  
Newcastle Under Lyme  
Staffordshire  
ST5 7XE  
United Kingdom



# Product Certificate

Appendix to Certificate number: 2504732

---

The following products belong to this certificate

<b>PRODUCT DESCRIPTION</b> DC type pipe interrupter with a permanent atmospheric vent, EPDM o-ring and DZR brass body incorporating a hose connection on the outlet. ATS3 – Without Production Surveillance.
<b>MODEL(S)</b> BT118.
<b>SIZE:</b> 3/8" BSP (M).
<b>SCOPE:</b> Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
<b>MARKING</b> WaterSaver etched on body.
<b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.
<b>BACKFLOW PROTECTION NOTES</b> Where the DC pipe interrupter is used, it must be installed so that the lowest point of the air aperture is not less than 150mm above the spillover level of the receiving receptacle, and have no valve, flow restrictor or tap on its outlet.
<b>ADDITIONAL NOTES</b> All water contact & exposed components satisfy opacity requirements.

## Extra Notes